


PRIVATE OFFICE WITH WINDOW CA TITLE 24 2019 DESIGN GUIDE RISER DIAGRAM



OPERATION:
 Switch ON/OFF
 On Level set for 50% dimming
 Motion sensor set for Vacancy
 Photocell limits max level in daylight zones
 Plug-load relay for 120V outlets operated by motion sensor on/off.



5229 Edina Industrial Blvd.
 Minneapolis, MN 55439
 952.829.1900 | ilc-usa.com

XX				Project:
NUMBER	REVISIONS	DATE	SHEET INFORMATION	
A	Code Riser CR0007	5-6-19	DATE:	5-6-19
C	Rev C Update	4-27-20	SCALE:	NONE
			DRAWN BY: JM	

PRIVAE OFFICE Title: WITH WINDOW CA TITLE 24 2019 RISER	
GO#	Sheet:
219xxxx	CR0007