


PRIVATE RESTROOM

ASHRAE DESIGN GUIDE 90.1 - 2013

RISER DIAGRAM


CAT-5 Data Cable For Network System Option



Local LS

Private Restroom 201

CAT-5 Cable Local Bus of EVO panel



G3-1-MZD
LS: 04
Rm: 201

OPERATION:
Switch ON/OFF
On Level set for 50% dimming
Motion sensor set for Occupancy On/Off
Pre-Program F7



5229 Edina Industrial Blvd.
Minneapolis, MN 55439
952.829.1900 | ilc-usa.com

XX				Project:
NUMBER	REVISIONS	DATE	SHEET INFORMATION	
E	Pre-Program	1-3-22	DATE:	1-3-22
			SCALE: NONE	
			DRAWN BY: JM	

Title:
PRIVATE RESTROOM
ASHRAE 90.1
RISER

GO#	Sheet:
222xxxxx	CR0201