


PRIVATE OFFICE WITH WINDOW IECC 2015 DESIGN GUIDE RISER DIAGRAM



OPERATION:
 Switch ON/OFF
 On Level set for 50% dimming
 Motion sensor set for Vacancy
 Photocell limits max level in daylight zones



5229 Edina Industrial Blvd.
 Minneapolis, MN 55439
 952.842.2564 | 800.922.8004
 ilc-usa.com

| XX | | | | Project: | PRIVAE OFFICE WITH WINDOW IECC 2015 RISER | Title: |
|-----------|-------------------|--------|-------------------|----------|---|--------|
| NUMBER | REVISIONS | DATE | SHEET INFORMATION | | | |
| A | Code Riser CR0407 | 5-6-19 | DATE: | 5-6-19 | | |
| 1 | - | - | SCALE: NONE | | | |
| | | | DRAWN BY: JM | | GO# | Sheet: |
| | | | | | 219xxxx | CR0407 |