


LightLEEDer High Voltage Divider and Barrier Installation Details



The right and left sides of the enclosure can be dedicated to different line voltages (120 or 277V) and would not require a high voltage divider. If the left or right relay section needs to be separated from top to bottom a high voltage divider can be field installed.

High Voltage Divider Installation:

1. Remove the fish paper barrier and retain the barrier and screws.
2. Align the high voltage divider between relays to be separated and secure with self tapping TEK screws provided.
3. Secure fish paper to mounting brackets with screws removed.