


LightSync G3-Wireless Switch Installation Details



Installing the LSG3-W Switch:

- Install remote mount LightSync G3 Wireless switch within radio proximity of the wireless relay or LLEVO-W controller it will be linked to.
- For best performance always mount the LSG3-W switch where the radio is not obstructed by metal enclosures or subject to equipment with high EMF radio noise. Plastic low voltage class-2 enclosures or switch mounting brackets are recommended if allowed by code, along with a plastic cover plate.
- Mount LSG3-W switch in standard 1-gang switch bracket or junction box using screws provided.
- Verify that the switch station is within 50 feet line of sight to the wireless relay or LLEVO-W controller it is intended to be linked to.
- Before installing LSG3-W switch, open battery door and install the provided battery. The wireless switch will automatically enter *link mode*, refer to Technical Bulletin TB0401 for wireless relay direct link directions.
- To link the LSG3-W switch to a LLEVO-W wireless controller refer to Technical Bulletin TB0402.