


77013482 Controllable Breaker Address/Count Switch Settings

COUNT	ADDRESS															
	01	02	03	04	05	06	07	08	09	0A	0B	0C	0D	0E	0F	10
0	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid
1	R01-04	R05-08	R09-12	R13-16	R17-20	R21-24	R25-28	R29-32	R33-36	R37-40	R41-44	R45-48	R49-52	R53-56	R57-60	R61-64
2	R01-08	R05-12	R09-16	R13-20	R17-24	R21-28	R25-32	R29-36	R33-40	R37-44	R41-48	R45-52	R49-56	R53-60	R57-64	Invalid
3	R01-12	R05-16	R09-20	R13-24	R17-28	R21-32	R25-36	R29-40	R33-44	R37-48	R41-52	R45-56	R49-60	R53-64	Invalid	Invalid
4	R01-16	R05-20	R09-24	R13-28	R17-32	R21-36	R25-40	R29-44	R33-48	R37-52	R41-56	R45-60	R49-64	Invalid	Invalid	Invalid
5	R01-20	R05-24	R09-28	R13-32	R17-36	R21-40	R25-44	R29-48	R33-52	R37-56	R41-60	R45-64	Invalid	Invalid	Invalid	Invalid
6	R01-24	R05-28	R09-32	R13-36	R17-40	R21-44	R25-48	R29-52	R33-56	R37-60	R41-64	Invalid	Invalid	Invalid	Invalid	Invalid
7	R01-28	R05-32	R09-36	R13-40	R17-44	R21-48	R25-52	R29-56	R33-60	R37-64	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid
8	R01-32	R05-36	R09-40	R13-44	R17-48	R21-52	R25-56	R29-60	R33-64	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid
9	R01-36	R05-40	R09-44	R13-48	R17-52	R21-56	R25-60	R29-64	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid
A	R01-40	R05-44	R09-48	R13-52	R17-56	R21-60	R25-64	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid
B	R01-44	R05-48	R09-52	R13-56	R17-60	R21-64	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid
C	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid
D	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid
E	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid
F	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid	Invalid



INTELLIGENT LIGHTING CONTROLS, INC.

5229 Edina Industrial Boulevard
 Minneapolis, Minnesota 55439
 Phone 952 829 1900
 FAX 952 829 1901
www.ilc-usa.com